

Re: Abutters notices

From matt schwaikert

Date Mon 11/4/2024 12:24 PM

To Miles Todaro

Hi Miles,

Unfortunately nothing back in today's mail either. I will plan on NOT being at the meeting tonight.....unless you say otherwise

The answer to the generator question: the generator will be mount to a deck made out of Pressure treated lumber. 4- 4"x4" posts (in-ground below frost line: 4ft) will support the deck so we can suspend the generator to BFE, plus 1'. In the proposed location the deck would be 4ft off of existing grade. This should allow plenty of room for water and potential flood debris to pass thought. We thought of 4"x4" posts to minimize any flood area displacement as opposed to larger post material. The total displacement will be 1 cubic ft which we will compensate for upon finish grade.

Thank you,
Matt

Matt's Landscaping
244 Route 7 South
Falls Village, CT 06031
860-824-1188
<http://www.mattslandscapingct.com>