

**From:** Fire Marshal <firemarshal@salisburyct.us>  
**Sent:** Wednesday, December 4, 2024 3:11 PM  
**To:** Abby Conroy <aconroy@salisburyct.us>  
**Subject:** re Fire protection water supply for Wake Robin Inn

Abby,

For any property, the plan approval process for major renovations or new buildings by the Fire Marshal's Office includes a consideration of the water supply for fire extinguishment operations. The Fire Chief for Lakeville Hose, Jason Wilson, would be consulted as needed for plan review, although the available water supply for any individual property is usually more relevant to any insurance company providing coverage for that property. We generally know for any building in Salisbury that a sufficient water supply will either be provided by hydrants and the municipal water system, from a drafting point or dry hydrant from a natural body of water, or by a tanker relay drawing from one of those two sources. Without knowing too many of the specifics about the available water supply for the Wake Robin Inn, I would say that the supply will be more than sufficient, given the proximity of hydrants and Wononskopomuc Lake across the street. As the project gets into the plan approval stage, and we are made aware of the full number and size of any proposed structures, we may or may not require, inasmuch as we are allowed to by the CT Fire Safety Code, additional water supply features, such as hydrants, drafting points, standpipe systems, etc.

John DeShazo



John D. DeShazo

Fire Marshal, Town of Salisbury, CT

27 Main Street, P.O. Box 548

Salisbury, CT 06068

(860)435-5196

firemarshal@salisburyct.us